

Bessemer Academy

Sample ID	Sample Date	Sample Time	Fixture Type	Cadmium (ppb)	Copper (ppb)	Iron (ppb)	Lead (ppb)	Zinc (ppb)	Location	Action
BSM3	9/19/2017	6:11 AM	DFS	<1.00	460	<500	2.07	363	First Floor South Near Restrooms	No Action Required
BSM4	9/19/2017	6:12 AM	DFS	<1.00	358	<500	1.61	317	First Floor South Near Restrooms	No Action Required
BSM5	9/19/2017	6:13 AM	TLF	3.85	831	<500	<1.00	1673	Staff Work Room	No Action Required
BSM6	9/19/2017	6:14 AM	TLF	<1.00	183	<500	<1.00	17.1	Staff Lounge	No Action Required
BSM7	9/19/2017	6:16 AM	KSF	<1.00	230	<500	6.23	482	Kitchen	No Action Required
BSM8	9/19/2017	6:17 AM	DFS	<1.00	277	<500	1.39	118	First Floor Near Gym	No Action Required
BSM9-L	9/19/2017	6:18 AM	DFS	<1.00	119	<500	<1.00	27.3	First Floor Near Gym Storage	No Action Required
BSM10-R	9/19/2017	6:19 AM	DFS	<1.00	158	<500	<1.00	35.7	First Floor Near Gym Storage	No Action Required
BSM11-L	9/19/2017	6:20 AM	DFS	<1.00	158	<500	<1.00	5.43	Second Floor New Wing	No Action Required
BSM12-R	9/19/2017	6:21 AM	DFS	<1.00	214	<500	<1.00	7.66	Second Floor New Wing	No Action Required
BSM13	9/19/2017	6:23 AM	DFS	<1.00	353	<500	<1.00	151	Second Floor South Hallway Near Rm 203	No Action Required
BSM14	9/19/2017	6:24 AM	DFS	<1.00	834	<500	1.45	618	Second Floor North Hallway Near Rm 205	No Action Required
BSM15-L	9/19/2017	6:25 AM	DFS	<1.00	185	<500	<1.00	17.6	Second Floor North Hallway Near Music Rm	No Action Required
BSM16-R	9/19/2017	6:26 AM	DFS	<1.00	141	<500	<1.00	13.2	Second Floor North Hallway Near Music Rm	No Action Required

Fixture Type: DFS - Drinking Fountain with single faucet, DFD - Drinking Fountain with double faucet, SC - Service Connection; KS - Kitchen Sink; TL - Teachers Lounge Sink