

Central High School

Sample ID	Sample Date	Sample Time	Fixture Type	Cadmium (ppb)	Copper (ppb)	Iron (ppb)	Lead (ppb)	Zinc (ppb)	Location	Action
CH1	4/24/2018	5:42 AM	SC-1S	<1.00	585	<500	<1.00	3.37	Backflow #1	No Action Taken
CH2	4/24/2018	5:45 AM	SC-1M	<1.00	2.24	<500	<1.00	1.91	Backflow #2	No Action Taken
CH4	4/24/2018	5:53 AM	DFS	<1.00	164	<500	<1.00	3.46	1st Floor Hallway near Kitchen	No Action Taken
CH5	4/24/2018	5:55 AM	DFS	<1.00	2300	<500	3.61	327	Cafeteria	No Action Taken
CH6	4/24/2018	5:56 AM	DFS	<1.00	2520	<500	1.01	315	Cafeteria	No Action Taken
CH7	4/24/2018	5:57 AM	IM	<1.00	10.4	<500	<1.00	5.61	Kitchen	No Action Taken
CH8-L	4/24/2018	5:58 AM	KSF	<1.00	434	<500	2.09	502	Kitchen	No Action Taken
CH8-R	4/24/2018	5:58 AM	KSF	<1.00	576	<500	2.12	603	Kitchen	No Action Taken
CH9	4/24/2018	6:00 AM	DFS	<1.00	373	1.42	<1.00	111	2nd Floor near Restrooms	No Action Taken
CH10	4/24/2018	6:01 AM	DFS	<1.00	354	<500	1.74	94.8	2nd Floor near Classroom #204	No Action Taken
CH11	4/24/2018	6:02 AM	DFS	<1.00	196	<500	2.28	1000	2nd Floor near Classroom #207	No Action Taken
CH12	4/24/2018	5:55 AM	DFS	<1.00	174	<500	<1.00	25.9	3rd Floor near Restrooms	No Action Taken
CH13	4/24/2018	5:56 AM	DFS	<1.00	277	<500	1.22	72.8	3rd Floor near Classroom #305	No Action Taken
CH14	4/24/2018	5:57 AM	DFS	<1.00	403	<500	2.63	60.8	3rd Floor near Main Office	No Action Taken
CH15	4/24/2018	6:00 AM	DFS	<1.00	264	<500	<1.00	42.0	4th Floor near Restrooms	No Action Taken
CH16	4/24/2018	6:02 AM	DFS	<1.00	300	<500	2.33	48.9	4th Floor near Classroom #407	No Action Taken
CH17	4/24/2018	6:03 AM	DFS	<1.00	150	<500	2.01	11.8	4th Floor near Classroom #410	No Action Taken
CH18	4/24/2018	6:04 AM	DFS	<1.00	480	<500	3.02	197	5th Floor near Restrooms	No Action Taken
CH19	4/24/2018	6:05 AM	DFS	<1.00	377	<500	2.12	65.4	5th Floor near Classroom #504	No Action Taken
CH20	4/24/2018	6:06 AM	DFS	<1.00	528	<500	5.88	58.1	5th Floor near Classroom #508	No Action Taken
SL 15SEC*	4/24/2018	5:40 AM		<1.00	38.5	<500	24.8	17.3	Meter	
SL 45SEC*	4/24/2018	5:41 AM		<1.00	24.3	<500	9.03	10.1	Meter	

Fixture Type: DFS - Drinking Fountain with single faucet, DFD - Drinking Fountain with double faucet, *SC - Service Connection Tap; KS - Kitchen Sink; TL - Teachers Lounge Sink

* Service Connection Tap is not a point for consumption water