

Fountain International Magnet School

Sample ID	Sample Date	Sample Time	Fixture Type	Cadmium (ppb)	Copper (ppb)	Iron (ppb)	Lead (ppb)	Zinc (ppb)	Location	Action
FIMS1	2/27/2018	6:10 AM	SC-1S	<1.00	12.1	<500	<1.00	5.42	Backflow #1	No Action Taken
FIMS2	2/27/2018	6:14 AM	SC-1M	<1.00	11.5	<500	<1.00	5.22	Backflow #2	No Action Taken
FIMS3	2/27/2018	6:15 AM	KSF	<1.00	132	<500	<1.00	253	Kitchen	No Action Taken
FIMS4	2/27/2018	6:17 AM	DFS	<1.00	276	<500	2.01	121	Cafeteria	No Action Taken
FIMS5	2/27/2018	6:19 AM	DFS	<1.00	37.3	<500	<1.00	2.20	Hallway Near Media Center	No Action Taken
FIMS6	2/27/2018	6:20 AM	DFS	<1.00	92.7	<500	<1.00	12.6	Hallway Near Main Office	No Action Taken
FIMS7	2/27/2018	6:20 AM	DFS	<1.00	112	<500	<1.00	18.9	Hallway Near Main Office	No Action Taken
FIMS8	2/27/2018	6:20 AM	KSF	<1.00	450	<500	<1.00	69.8	Main Office	No Action Taken
FIMS9	2/27/2018	6:22 AM	DFS	<1.00	508	<500	<1.00	31.1	Classroom #1	No Action Taken
FIMS10	2/27/2018	6:25 AM	KSF	<1.00	32.5	<500	<1.00	197	Cafeteria Sink	No Action Taken
SL 15SEC	2/27/2018	5:53 AM		<1.00	21.5	<500	2.97	11.0	Meter	No Action Taken
SL 45SEC	2/27/2018	5:53 AM		<1.00	14.0	<500	1.74	8.65	Meter	No Action Taken

Fixture Type: DFS - Drinking Fountain with single faucet, DFD - Drinking Fountain with double faucet, *SC - Service Connection Tap; KS - Kitchen Sink; TL - Teachers Lounge Sink

* Service Connection Tap is not a point for consumption water