

**Franklin Elementary**

Sample ID	Sample Date	Sample Time	Fixture Type	Cadmium (ppb)	Copper (ppb)	Iron (ppb)	Lead (ppb)	Zinc (ppb)	Location	Action
FRKN1	11/28/2017	6:13 AM	SC-1S	<1.00	100	<500	1.21	76.4	Backflow Valve	No Action Taken
FRKN2	11/28/2017	6:18 AM	SC-1M	<1.00	246	<500	8.55	149	Backflow Valve	No Action Taken
FRKN3	11/28/2017	6:19 AM	DFS	3.01	46.0	<500	1.79	2950	Basement hallway	No Action Taken
FRKN4	11/28/2017	6:21 AM	DFS	<1.00	257	<500	<1.00	337	Cafeteria hallway	No Action Taken
FRKN5	11/28/2017	6:22 AM	DFS	<1.00	194	<500	<1.00	26.2	Cafeteria hallway	No Action Taken
FRKN6	11/28/2017	6:23 AM	DFS	<1.00	1170	<500	<1.00	277	Cafeteria	No Action Taken
FRKN7-L	11/28/2017	6:24 AM	KSF	<1.00	201	<500	1.37	1260	Kitchen	No Action Taken
FRKN7-R	11/28/2017	6:24 AM	KSF	<1.00	229	<500	1.45	784	Kitchen	No Action Taken
FRKN8	11/28/2017	6:26 AM	DFS	<1.00	722	<500	<1.00	62.4	Gymnasium	No Action Taken
FRKN9	11/28/2017	6:27 AM	DFS	<1.00	604	<500	<1.00	28.2	Gymnasium	No Action Taken
FRKN10	11/28/2017	6:28 AM	DFS	<1.00	43.9	<500	<1.00	1450	Main hallway near office	No Action Taken
FRKN11	11/28/2017	6:29 AM	KSF	<1.00	657	<500	<1.00	61.3	Media Center	No Action Taken
FRKN12	11/28/2017	6:30 AM	FF	<1.00	609	<500	2.44	340	Main office	No Action Taken
FRKN13	11/28/2017	6:31 AM	DFS	<1.00	2320	<500	<1.00	145	ESS classroom #5	No Action Taken
FRKN14	11/28/2017	6:32 AM	DFS	<1.00	213	<500	<1.00	198	South hallway near room #22	No Action Taken
FRKN15	11/28/2017	6:33 AM	DFS	<1.00	526	<500	<1.00	72.6	South hallway near room #22	No Action Taken
FRKN16	11/28/2017	6:37 AM	TL	<1.00	332	<500	<1.00	325	Teachers Lounge	No Action Taken
FRKN17	11/28/2017	6:38 AM	DFS	<1.00	553	<500	<1.00	67.8	West main hallway near room #13	No Action Taken
FRKN18	11/28/2017	6:39 AM	DFS	<1.00	530	<500	<1.00	35.2	West main hallway near room #13	No Action Taken
SL 15SEC	11/28/2017	5:54 AM		<1.00	15.9	<500	<1.00	12.7	Meter	No Action Taken
SL 45SEC	11/28/2017	5:54 AM		<1.00	13.1	<500	<1.00	12.0	Meter	No Action Taken

**Fixture Type: DFS - Drinking Fountain with single faucet, DFD - Drinking Fountain with double faucet, \*SC - Service Connection Tap; KS - Kitchen Sink; TL - Teachers Lounge Sink**

\* Service Connection Tap is not a point for consumption water