

**Pueblo Academy of Arts**

Sample ID	Sample Date	Sample Time	Fixture Type	Cadmium (ppb)	Copper (ppb)	Iron (ppb)	Lead (ppb)	Zinc (ppb)	Location	Action
PAA1	4/12/2018	5:45 AM	SC-1S	<1.00	2.86	<500	<1.00	1.94	Backflow #1	No Action Taken
PAA2	4/12/2018	5:50 AM	SC-1M	<1.00	2.76	<500	<1.00	1.66	Backflow #2	No Action Taken
PAA3-R	4/12/2018	5:54 AM	DFD	<1.00	435	<500	69.3	546	Cafeteria	Replaced water lines and fountain
PAA4	4/12/2018	5:55 AM	KSF	<1.00	42.3	<500	3.79	467	Kitchen	No Action Taken
PAA5	4/12/2018	5:56 AM	IM	<1.00	14.1	<500	<1.00	9.42	Kitchen Ice Machine	No Action Taken
PAA6-R	4/12/2018	5:58 AM	DFD	<1.00	60.5	<500	4.87	88.9	50 Wing Hallway	No Action Taken
PAA7-L	4/12/2018	5:59 AM	DFD	<1.00	477	<500	43.6	360	Cafeteria	Replaced water lines and fountain
PAA7-R	4/12/2018	6:00 AM	DFD	<1.00	451	<500	34.3	425	Cafeteria	Replaced water lines and fountain
PAA8-L	4/12/2018	6:02 AM	DFD	<1.00	65.9	<500	14.3	427	10 Wing Hallway	Replaced water lines and fountain
PAA8-R	4/12/2018	6:02 AM	DFD	<1.00	56.8	<500	10.2	85.8	10 Wing Hallway	No Action Taken
PAA9	4/12/2018	6:03 AM	KSF	<1.00	385	<500	7.69	1120	Teachers Lounge	No Action Taken
PAA10-L	4/12/2018	6:06 AM	DFD	<1.00	40.3	<500	4.99	125	40 Wing Hallway	No Action Taken
PAA10-R	4/12/2018	6:06 AM	DFD	<1.00	29.2	<500	3.06	29.2	40 Wing Hallway	No Action Taken
PAA11-L	4/12/2018	6:09 AM	DFD	<1.00	84.3	<500	12.5	395	20 Wing Hallway	No Action Taken
PAA11-R	4/12/2018	6:10 AM	DFD	<1.00	30.6	<500	3.33	75.4	20 Wing Hallway	No Action Taken
PAA12-L	4/12/2018	6:13 AM	DFD	<1.00	62.8	<500	13.4	127	30 Wing Hallway	Replaced water lines and fountain
PAA12-R	4/12/2018	6:13 AM	DFD	<1.00	62.0	<500	7.50	196	30 Wing Hallway	No Action Taken
SL 15SEC	4/10/2018	6:43 AM		<1.00	517	<500	110	21.6	Meter	
SL 45SEC	4/10/2018	6:43 AM		<1.00	59.0	<500	10.5	18.0	Meter	

**Fixture Type: DFS - Drinking Fountain with single faucet, DFD - Drinking Fountain with double faucet, \*SC - Service Connection Tap; KS - Kitchen Sink; TL - Teachers Lounge Sink**

\* Service Connection Tap is not a point for consumption water